

# Hertfordshire County Scout Council

## Phasels Wood Activity Centre

### Fire Risk Assessment

#### 1 Building - Storm Hut

**Designated use** - Indoor hall

**Approximate size** – 18m x 6m

**Number of beds** – N/A Non sleeping accommodation

**Number of floors** – Single storey

**Roof construction** – Felt sheeting on timber frame

**Walls** – Timber frame all wood clad

**Internal linings**- Timber

**Floors** – Concrete with vinyl overlaid

**Means of escape** – Via fire exit doors (it is understood that whenever the premises are occupied no exit door is secured in such a manner that it is not easily and immediately openable)

**Fire Fighting equipment** – 1 x FOAM, 1 x WATER type extinguishers.

**Fire Alarm system** – N/A

**Heating/hot water/cooking** – N/A

**Electrical installation** - 240 volt supply throughout. Fuse board fitted in main hall.

**General Lighting** - 240 volt supply throughout

**Emergency Lighting** – Non maintained throughout

**Signs and Notices** – All to current standards

**Furnishings** – Only fire retardant furnishings as fitted in buildings are permitted.

**2 Personnel Involved**                      **Instructors/Staff/Campers/Visitors**  
**Number of people**                      **1 – 100**

<b>3 Potential Hazards</b>	<b>4 Risk Level</b>
1 Waste	Low
2 Doors	Low
3 Smoking	Low
4 Cleaning Equipment and chemicals	Low
5 Electrical equipment	Low

**5 Measures Taken to Control Hazards**

- 1 Ensure floor area kept clear, combustible material tidied away and waste bins cleared regularly.
- 2 Ensure doors are open whilst building is in use. Ensure signage is present
- 3 Signs and ask people not to smoke indoors.
- 4 Store cleaning materials in designated areas, chemicals secured, COSHH and product specific training as appropriate. Remove industrial/flammable chemicals from buildings.
- 5 Use as per manufacturers instructions, PAT regime in place, minimise trailing cables, do not overload fuses, appropriate trips on circuits

**NOTE - Extinguishers are present and tested yearly. All occupiers are supplied “Fire Action” information prior to arrival and should understand what to do in the case of an emergency.**

Compilation date -	25/03/2008	Compiled by :- DS
Review period -	12 Months	
Reference Number -	PW/FIRE008	